



CERTIFICATE

FOR EUROPEAN PRODUCT SAFETY

Reference No. SE-S-2300210

Junction box

Type designation: 5697/5, 5695/5, 5650, 5652

Certificate holder: STEAB S.r.l.
Via G. Marconi 1/3
Scopeti, IT-50068 Rufina (FI)
ITALY

The product complies with the standard(s): EN 60998-2-1:2004

Date of expiry: 27 February, 2028

EU Directive information: According to the principle of presumption of conformity, this certificate constitutes support for an EU Declaration of Conformity to the Low Voltage Directive 2014/35/EU.

Additional information in Appendix

Certification Body: Intertek Semko AB, Product Certification **Place:** Kista - Stockholm

Signed:  **Date:** 27 February, 2023

Quan Li

APPENDIX:

Reference No. SE-S-2300210

Technical Data:

Type designation 5697/5, 5695/5, 5650
Rated voltage (V) 250 VAC
IP-Class IP68 (1,3 m; 24h)
Number of terminals 5 (5697/5 & 5695/5); 6 (5650)
Rated connecting cap 1,5 mm²
Trademark 
Test Report 2110788STO-001
Product information Connection boxes with internal screw terminal block. Cable Ø 6,5-12,0 mm. 3 cable entries for 5697/5 and 5695/5. Two cable entries for 5650.

Type designation 5652
Rated voltage (V) 450 VAC
IP-Class IP68 (1,3 m; 24h)
Number of terminals 5
Rated connecting cap 6 mm²
Trademark 
Test Report 2110788STO-001
Product information Connection boxes with internal screw terminal block. Cable Ø 7,5-16,0 mm or 16-22 mm (depends on cable entry). 6 cable entries.

Manufacturing Sites:

STEAB S.r.l.
Via G. Marconi, 1/3
Scopeti, IT-50068 Rufina (FI)
ITALY

According to the principle of presumption of conformity, this certificate, which includes production control, constitutes support for an EU Declaration of Conformity according to the Low Voltage Directive 2014/35/EU. This presumption can expire before end of validity of this certificate due to new issued Standard or Amendment and changes within the EU legislation.

Certification Body: Intertek Semko AB, Product Certification **Place:** Kista - Stockholm

Signed:  **Date:** 27 February, 2023

Quan Li